



Progress Meeting Agenda #18
September 11, 2024 – 11:00 AM
Swisher City Hall
66 2nd St. SW

Sanitary Sewer and Utility Improvements
City of Swisher, IA

1. Progress

a. This Period:

- 1) Completed storm intake tops and throats on I-212, I-213, I-214 on Howard Ave.
- 2) Began back filling curbs and placing topsoil on Howard Ave.
- 3) Set up sanitary sewer bypass on 3rd Street.
- 4) Adjusted traffic control to open 2nd Street and close 3rd Street to through traffic.
- 5) Started the sanitary sewer installation on 3rd Street.

b. Next Week:

- 1) Set precast storm intake tops and pour throats.
- 2) Continue sidewalk layout and grading.
- 3) Continue with underground work on 3rd Street.
- 4)

c. Looking Ahead:

- 1) 2 week look ahead work
 - a) Sidewalk paving
 - b)

2. Schedule Updates:

- a. Underground work on a portion of 3rd Street. (Phase 2)

3. Public Comment

- a. 309 Jefferson well problems.
- b. Additional driveway request at 76 Howard.

4. Old Business

- a. Larry Greiner requested that his property corner pins be re-established. Survey information was obtained from the County.
- b. Mark Ironside property pins to be re-established.
- c. Storm water drainage on 2nd street at Swisher Creek.

5. New Business

- a.
- b.

6. Utilities

- a. Continue to keep locates fresh.
- b. Alliant Energy relocation of poles and transformer on Howard Ave.
- c. South Slope adjustment of pedestals.
- d.

7. Requests for Information

- a) RFI-1 Water main testing. Air test only until put into service.
- b) RFI-2 Water main testing will be completed prior to service installation.
- c) RFI-3 Proposed Water Main route directly across Division St. Original route to be maintained.
- d) RFI-4 Backfill material over the storm water piping. Granular backfill is to be used.

8. Instruction to Contractor

- a) ITC 001, 2/7/2024 Storm Sewer Gasket Clarification
- b) ITC 002, 5/26/2024 Additional water main valve when crossing Swisher Creek.
- c) ITC 003, 6/25/2024 Water main scope reduction at Swisher Creek.
- d) ITC 003, 6/25/2024 CMP replacement under 2nd street Swisher Creek crossing.

9. Submittals

- a. Review of Shop Drawing Log.

10. Change Orders

- a. None pending.

11. Pay Estimates

- a. Pay application #5 was reviewed at the 9/9/24 Council Meeting.
- b. Pay application #6 will be generated on 9/30/24.

12. General Discussion/Questions

- a.
- b.

Next Meeting: September 18, 2024 at 11:00 AM.